

**ASANSOL ENGINEERING COLLEGE, ASANSOL**  
**MODROBS 2008-09 Department of MCA (F.No.-8024/RID/BOR/MOD-245/2008-09)**


Sealed quotations are invited from the venders having trade license and vat registration certificate for the supply of following materials for MODROBS for DBMS Lab in the Department of MCA.

1) UPS -1 no. with specification as follows

Slno.	Specification	Details			
1.	Output Power	10KVA			
2.	Battery Voltage	240VDC			
3.	Efficiency				
	i) Inverter	>=93%			
	ii) Overall	>=90%			
4.	Input Rating;				
i) Voltage	ii) Phase	iii) Frequency			
330-470V	3 Phase(on line)	47-53 Hz			
5.	Output Rating;				
i) Voltage	ii) Phase	iii) Regulation	iv) Power Factor	v) Frequency	vi) Sync range
230 V	1 Phase	(+/-) 1.5%	0.8 Lagging	50 HZ (+/-) 0.1%	48-52Hz
6.	Back UP	30 Minutes/20 Minutes			

2) Desktop -20 no. with specification as follows

1.	Processor	-----	Intel Core 2 Duo 2.26 GHz
2.	Motherboard	-----	Intel Original with 800FSB
3.	RAM	-----	2 GB DDR2
4.	Hard Disk	-----	280GB Sata
5.	ATX Full Tower Cabinet		
6.	Multimedia Keyboard		
7.	Optical Mouse		
8.	Monitor	-----	17'' TFT

  
 Principal-In-Charge  
 Asansol Engineering College